



**ADDENDUM #2**  
**ROOF REPLACEMENT**  
**FREDERICK BREWSTER ELEMENTARY SCHOOL**  
**DURHAM, CT**

Hibbard & Rosa Architects, L.L.C.  
Middletown, Connecticut

The following changes, revisions, and/or additions are hereby made a part of the Contract Documents and shall supersede previously issued documents and shall become a part of the contract documents.

Date: May 14, 2015

Information to Bidders:

The of the small 7'6" x 7'-6" roof located to the lower left hand corner of the Gymnasium is included in the scope of work.

Information to Bidders:

Detail 2/A6; The base sheet and cap sheet are self adhering.

Information to Bidders:

At the entrance canopy install the SA (self adhering) base sheet up and over the ridge (where the vapor barrier is indicated).

Information to Bidders:

Detail 1/A7; this condition is located at the base of the existing Gymnasium wall above the lower classroom wing.

Information to Bidders:

Detail 2/A7; this condition is located at the change in roof levels just above the HVAC unit on dunnage (Sheet A-1).

Information to Bidders:

Provide and install two vertical rainwater leaders for the new standing seam metal roof to be installed on the Gymnasium.

**END OF ADDENDUM #2**